

MAINTENANCE LOG SHEET

TABLE BAY HOTEL POOL

Date	Checked By:	Daily					Weekly			Monthly	Comments
		Check Auto Doser †pH 6.8-7.0 NOT ABOVE 7.2	Check Level of Acid Drum (Dilute 5L Pool Acid in 20L Water**)	Check E-Box Conductivity Oxygen -2A; Cu 450mA	Visual Check Water Quality & Pool Clean & Free of Debris	†Cu 0.6-0.8ppm	Stock Check: 1. 25L Drum 50% Hyprox; 2. Calcium Chloride Hardness Flakes	†Manual pH Test	Back Wash*	Calcium Hardness 250ppm	
		Monday									
		Tuesday									
		Wednesday									
		Thursday									
		Friday									
		Saturday									
		Sunday									

* Weekly in Winter and 2x per week in Summer (Keep eye on Pressure Gauge - if drops Back Wash)

†ALWAYS CHECK PH FIRST BEFORE COPPER TO AVOID FALSE COPPER READING

PS: When sampling take water as deep down as possible

**Always add Acid to Water and NOT Water to Acid